

Model No.: Cathodic Isolator – CI – 100

1 cycle	⊕ 50 Hz rms	94 kA	⊕ 60 Hz rms	100 kA
3 cycles	" "	75 kA	" "	80 kA
10 cycles	" "	47 kA	" "	50 kA
30 cycles	" "	34 kA	" "	36 kA

Model No.: Cathodic Isolator – CI – 90

1 cycle	⊕ 50 Hz rms	85 kA	⊕ 60 Hz rms	90 kA
3 cycles	" "	66 kA	" "	70 kA
10 cycles	" "	42 kA	" "	45 kA
30 cycles	" "	34 kA	" "	36 kA

Model No.: Cathodic Isolator – CI – 85

1 cycle	⊕ 50 Hz rms	80 kA	⊕ 60 Hz rms	85 kA
3 cycles	" "	56 kA	" "	60 kA
10 cycles	" "	38 kA	" "	40 kA
30 cycles	" "	28 kA	" "	30 kA

Model No.: Cathodic Isolator – CI – 60

1 cycle	⊕ 50 Hz rms	56 kA	⊕ 60 Hz rms	60 kA
3 cycles	" "	38 kA	" "	40 kA
10 cycles	" "	24 kA	" "	26 kA
30 cycles	" "	19 kA	" "	20 kA

Model No.: Cathodic Isolator – CI – 50

1 cycle	⊕ 50 Hz rms	47 kA	⊕ 60 Hz rms	50 kA
3 cycles	" "	38 kA	" "	40 kA
10 cycles	" "	23 kA	" "	25 kA
30 cycles	" "	17 kA	" "	18 kA

Model No.: Cathodic Isolator – CI – 45

1 cycle	⊕ 50 Hz rms	42 kA	⊕ 60 Hz rms	45 kA
3 cycles	" "	33 kA	" "	35 kA
10 cycles	" "	22 kA	" "	23 kA
30 cycles	" "	17 kA	" "	18 kA

Model No.: Cathodic Isolator – CI – 40

1 cycle	⊕ 50 Hz rms	38 kA	⊕ 60 Hz rms	40 kA
3 cycles	" "	28 kA	" "	30 kA
10 cycles	" "	19 kA	" "	20 kA
30 cycles	" "	14 kA	" "	15 kA

Model No.: Cathodic Isolator – CI – 30

1 cycle	⊕ 50 Hz rms	28 kA	⊕ 60 Hz rms	30 kA
3 cycles	" "	19 kA	" "	20 kA
10 cycles	" "	12 kA	" "	13 kA
30 cycles	" "	9 kA	" "	10 kA

Model No.: Cathodic Isolator – CI – 10

1 cycle	⊕ 50 Hz rms	9 kA	⊕ 60 Hz rms	10 kA
3 cycles	" "	7.4 kA	" "	7.9 kA
10 cycles	" "	5.3 kA	" "	5.6 kA
30 cycles	" "	3.9 kA	" "	4.2 kA

Model No.: Cathodic Isolator – CI – 5

1 cycle	⊕ 50 Hz rms	4.7 kA	⊕ 60 Hz rms	5 kA
3 cycles	" "	3.5 kA	" "	3.7 kA
10 cycles	" "	2.6 kA	" "	2.8 kA
30 cycles	" "	2.0 kA	" "	2.2 kA

no.	date	by	revision	chk'd by	date
0					
1					designed
2					W.B.R.
3					detailed
4					M.A.
5					checked
6					W.B.R.
7	JAN 23/2007	M.A.	TITLEBLOCK REVISED TO NEW FORMAT		

**INTERPROVINCIAL
CORROSION CONTROL
COMPANY LIMITED**
 930 Sheldon Court
 Burlington Ontario Canada
 Ph: (905) 634-7751 Fax: (905) 333-4313
 Copyright 2007

**RUSTROL®
SYSTEMS**
CATHODIC ISOLATOR®
isolator | cathodic
 drawing no. CI-00 rev. 7