


TYPICAL DC-DECOUPLER™ ENCLOSURE:

- ATEX & IECEx CERTIFIED ENCLOSURE
- FIBREGLASS REINFORCED POLYESTER
- IP67 (CERTIFIED); EQUIVALENT TO NEMA 4,4X,6P
- TYPICAL OVERALL DIMENSIONS FOR STANDARD RUSTROL® DC-DECOUPLER™ MODEL: DCD; DIMENSIONS ARE MODEL SPECIFIC.



NOTES:

- 1) NOT DRAWN TO SCALE
- 2) NOMINAL DIMENSIONS
- 3) ALL DIMENSIONS ARE APPROXIMATE.
- 4) ALL DIMENSIONS ARE SHOWN WITH BOTH METRIC & IMPERIAL UNITS AND ARE GOVERNED BY THE IMPERIAL MEASUREMENTS AS SHOWN.
- 5) TYPICAL INSTALLATION ONLY. VARIATIONS ARE COMMON BASED ON THE SITE REQUIREMENTS. ALL NOTED (*) DETAILS ARE PROVIDED AS SUGGESTIONS ONLY, AND ARE TO BE PROVIDED BY OTHERS. ALL NOTED (*) DETAILS ARE NOT INCLUDED WITH RUSTROL® PRODUCTS.
- 6) CABLE LENGTH IS RECOMMENDED NOT TO EXCEED 2 METERS IN EITHER DIRECTION TO AND FROM THE DC-DECOUPLER™ DCD-ATEX.
- 7) WHILE PUBLISHED STATEMENTS ARE BELIEVED TO BE ACCURATE, THEY ARE OFFERED AS SUGGESTIONS ONLY. ANY USE THEREOF IS AT THE USER'S INDEPENDENT DISCRETION.
- 8) THIS DRAWING REMAINS THE PROPERTY OF INTERPROVINCIAL CORROSION CONTROL COMPANY LTD

No.	Date	By	Revision	Chk'd By	Date
0	MAY 28/2015	H.O.	ISSUED FOR REVIEW	<i>AE</i>	MAY 28/2015

**INTERPROVINCIAL
CORROSION CONTROL
COMPANY LIMITED**

930 Sheldon Court
Burlington Ontario Canada
Ph: (905) 634-7751 Fax: (905) 333-4313

www.Rustrol.com
Copyright 2015



Project
TYPICAL INSTALLATION OF
RUSTROL® DC-DECOUPLER™
MODEL: DCD-ATEX-DT

Drawing No.
DCD-03

Rev.
0